



## **Addendum #2**

Issue Date: May 15, 2018

Project: Memorial Hospital of Texas County – Roof Restoration and Replacement at Designated Areas

---

The following are additions and changes to the Specifications and shall become a part of the contract documents. Where items in the Specifications or Drawings are supplemented below, all original requirements shall remain in place.

---

Amended answers to previously submitted questions:

Disregard Answer #9 – Roof Replacement Areas and Answer #5 – Roof Restoration Areas issued as part of Addendum #1.

Gas and electrical lines shall remain in place and functional during the project. The two electrical boxes located on roof number 12 will however, need to be raised.

Walk way pads shall also be placed below wood blocking under condenser units.

End of Addendum #2 – 1 Page Total