

THEREFORE, BE IT RESOLVED, the Board of County Commissioners of Texas County, Oklahoma, does hereby consent to the placement of a distribution line according to the requirements as set forth in the completed Permit Application attached. With the following special instruction to be included:

All requirements of the permit must be met and it shall be bored.

PERMIT # 71-14-15 Granted this 16th day of March 20 15.

BOARD OF COUNTY COMMISSIONERS

Richard Bryan
Chairman

Jack Starn
Member

Ted Keeling
Member



ATTEST:

Maia Hackinghead
Texas County Clerk

**STATE OF OKLAHOMA
TEXAS COUNTY
BORING ELECTRIC CROSSING
LINE INSTALLATION**
(Revised November 3, 2014)

permit 3 OF 13

We, the undersigned, hereby petition the Texas County Board of County Commissioners to grant a permit for a public service, pipeline crossing, or line installation as described below and in accordance with the provisions as listed.

ELECTRIC LINE OWNER

CONSTRUCTION COMPANY

Name Goodwell Wind Project, LLC

Name RES America Construction Inc.

Contact Don Miller

Contact Darren Pence PM. or Greg Sievers APM

Address 3636 Nobel Drive, Suite 475

Address 11101 W. 120th Ave, Suite 400

City San Diego State CA Zip 92122

City Broomfield State CO Zip 80021

Phone (858) 731-5022

Phone 303-439-4200 corp. 580-349-0081 local
Site: 2142 CR-HH, Goodwell, OK 73939

TYPE OF INSTALLATION

Electric Gas Oil Water Telephone Sewer Other _____

The installation will be made in the following manner:

Boring Pushing Overhead Crossing Other _____

A permit to erect, construct and maintain a 34.5KV Electric line and fiber optic along, upon and across the hereinafter said county highway or road for the purpose of transporting, selling, and using Electricity. **Exhibit A & B** attached clearly illustrating work to be performed and locations is further described as follows:

LOCATION #3:

Start point in the SE Qtr. of the SE Qtr. of Section 29 Township 1-N Range 13-E

Crossing or parallel to county road number crossing west to east on Mile 20 road

Ending point in the SW Qtr. of the SW Qtr. of Section 28 Township 1-N Range 13-E

PIPELINES

Size _____
Alloy/Material _____
Contents _____
Mfg. Test Pressure _____
Working Pressure _____
Max. Operating Pressure _____

ELECTRIC

Voltage 34.5kV
Conductor Size 1250kcmil
Type of Structure N/A
Ruling Span N/A

COMMUNICATIONS

Wires/Pairs/Strands 48-count fiber
Gauge _____
Cable Type _____

CASING

Size 4" & 8"
Alloy/Material HDPE
Wall Thickness 1/2"